

Mr. Chris Norris
Mirant Sugar Creek, LLC
5900 Darwin Road
West Terre Haute, IN 47885

Re: 167-15906-00123
First Notice Only Change to
MSOP 167-12208-00123

Dear Mr. Norris:

Mirant Sugar Creek, LLC was issued a minor source operating permit on May 9, 2001, for a natural gas merchant power plant. A letter requesting a change in the Authorized Individual, source, mailing address and phone number was received on July 19, 2002. Pursuant to the provisions of 326 IAC 2-6.1-6(d)(2) the permit is hereby administratively amended as follows:

Condition A.1 General Information has been changed. Deletions are marked with a ~~strikeout~~ and the new information is in **bold**. Because of potential future changes in personnel and to avoid excessive administrative permit amendments, only job titles are being listed. The source address change a change in the addressing system by the post office. The source did not physically relocate. In addition to the change in personnel, the mailing address and phone number changed. The address change was made on the cover page and the reporting forms of the permit as well.

A.1 General Information [326 IAC 2-5.1-3(c)] [326 IAC 2-6.1-4(a)]

The Permittee owns and operates a natural gas merchant power plant.

Authorized Individual:	Kirk Covington Plant Manager
Source Address:	6500 5900 Darwin Road, West Terre Haute, IN 47885
Mailing Address:	115 Perimeter Center West, Atlanta, GA 30338-4780 5900 Darwin Road, West Terre Haute, IN 47885
Phone Number:	(678) 579-3094 (812) 538-2100
SIC Code:	4911
County Location:	Vigo
County Status:	Maintenance Attainment SO ₂ ; Attainment for NO _x , CO, PM ₁₀ , Lead
Source Status:	Major, under PSD rules

All other conditions of the permit shall remain unchanged and in effect. Please find a copy of the entire MSOP with the revision.

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-5. If you have any questions on this matter, please contact Janet Mobley, of my staff, at 317-232-8369 or 1-800-451-6027, press 0 and ask for extension 2-8369.

Sincerely,

Paul Dubenetzky, Chief
Permits Branch
Office of Air Quality

PD/jm

Attachment: Revised MSOP permit

cc: File - Vigo County

Vigo County Health Department

Air Compliance Section Inspector - Jim Thorpe

Vigo Air Pollution Control

Compliance Data Section - Karen Nowak
Permit Review Section II - Janet Mobley

NEW SOURCE CONSTRUCTION PERMIT
Prevention of Significant Deterioration (PSD) Permit
Office of Air Quality
and
Vigo County Air Pollution Control

Mirant Sugar Creek LLC
5900 Darwin Road
West Terre Haute, IN 47885

(herein known as the Permittee) is hereby authorized to construct and operate subject to the conditions contained herein, the emission units described in Section A (Source Summary) of this permit.

This permit is issued to the above mentioned company under the provisions of 326 IAC 2-1.1, 326 IAC 2-5.1, 326 IAC 2-6.1 and 40 CFR 52.780, with conditions listed on the attached pages.

This permit is also issued under the provisions of 326 IAC 2-2, 40 CFR 52.21, and 40 CFR 52.124 (Prevention of Significant Deterioration), with conditions listed on the attached pages.

Construction Permit No.: CP 167-12208-00123	
Issued by: Paul Dubenetzky, Branch Chief Office of Air Quality	Issuance Date: May 09, 2001

First Significant Modification No.: 167-15295, issued July 24, 2002

First Notice Only Change No.: 167-15906	Pages Affected: 5, 39-43
---	--------------------------

Issued by: Paul Dubenetzky, Branch Chief Office of Air Quality	Issuance Date:
--	----------------

TABLE OF CONTENTS

A	SOURCE SUMMARY	5
A.1	General Information [326 IAC 2-5.1-3(c)] [326 IAC 2-6.1-4(a)]	
A.2	Emission Units and Pollution Control Equipment Summary	
A.3	Part 70 Permit Applicability [326 IAC 2-7-2]	
A.4	Acid Rain Permit Applicability [326 IAC 2-7-2]	
B	GENERAL CONSTRUCTION CONDITIONS	7
B.1	Permit No Defense [IC 13]	
B.2	Definitions	
B.3	Effective Date of the Permit [IC 13-15-5-3]	
B.4	Revocation of Permits [326 IAC 2-1.1-9(5)]	
B.5	First Time Operation Permit [326 IAC 2-6.1]	
B.6	Phase Construction Time	
B.7	BACT Determination for Phase Constructions	
B.8	Local Agency Requirement	
B.9	NSPS Reporting Requirements	
C	SOURCE OPERATION CONDITIONS	10
C.1	PSD Major Source Status [326 IAC 2-2]	
C.2	Preventive Maintenance Plan [326 IAC 1-6-3]	
C.3	Source Modification [326 IAC 2-7-10.5]	
C.4	Inspection and Entry [326 IAC 2-5.1-3(e)(4)(B)] [326 IAC 2-6.1-5(a)(4)]	
C.5	Transfer of Ownership or Operation [326 IAC 2-6.1-6(d)(3)]	
C.6	Permit Revocation [326 IAC 2-1-9]	
C.7	Opacity [326 IAC 5-1]	
C.8	Fugitive Dust Emissions [326 IAC 6-4]	
C.9	Stack Height [326 IAC 1-7]	
C.10	Performance Testing [326 IAC 3-6]	
C.11	Compliance Monitoring [326 IAC 2-1.1-11]	
C.12	Maintenance of Monitoring Equipment [IC 13-14-1-13]	
C.13	Monitoring Methods [326 IAC 3]	
C.14	Compliance Monitoring Plan - Failure to Take Response Steps [326 IAC 1-6]	
C.15	Actions Related to Noncompliance Demonstrated by a Stack Test	
	Record Keeping and Reporting Requirements	
C.16	Malfunctions Report [326 IAC 1-6-2]	
C.17	Monitoring Data Availability [326 IAC 2-6.1-2] [IC 13-14-1-3]	

- C.18 General Record Keeping Requirements [326 IAC 2-6.1-2]
- C.19 General Reporting Requirements [326 IAC 2-1.1-11] [326 IAC 2-6.1-2] [IC 13-14-1-13]

D.1 Simple Cycle Operation (Four Combustion Turbines)19

Emission Limitations and Standards

- D.1.1 Prevention of Significant Deterioration [326 IAC 2-2]
- D.1.2 Particulate Matter (PM/PM₁₀) Emission Limitations for Combustion Turbines
- D.1.3 Opacity Limitations
- D.1.4 Startup and Shutdown Limitations for Combustion Turbines
- D.1.5 Nitrogen Oxides (NO_x) Emission Limitations
- D.1.6 Carbon Monoxide (CO) Emission Limitations
- D.1.7 Sulfur Dioxide (SO₂) Emission Limitations
- D.1.8 Volatile Organic Compound (VOC) Emission Limitations
- D.1.9 40 CFR 60, Subpart GG (Stationary Gas Turbines)
- D.1.10 Formaldehyde Limitations
- D.1.11 Operational Limitations
- D.1.12 Preventive Maintenance Plan [326 IAC 1-6-3]

Compliance Determination Requirements

- D.1.13 Performance Testing
- D.1.14 40 CFR 60, Subpart GG Compliance Requirements (Stationary Gas Turbines)
- D.1.15 Continuous Emission Monitoring

Record Keeping and Reporting Requirements

- D.1.16 Record Keeping Requirements
- D.1.17 Reporting Requirements

D.2 Combined Cycle Operation (Four Combustion Turbines w/Duct Burners)26

Emission Limitations and Standards

- D.2.1 Prevention of Significant Deterioration [326 IAC 2-2]
- D.2.2 Particulate Matter Emission Limitations for Combustion Turbines/Duct Burners
- D.2.3 Opacity Limitations
- D.2.4 Particulate Matter Emission Limitations for Cooling Towers
- D.2.5 Startup and Shutdown Limitations for Combustion Turbines
- D.2.6 Nitrogen Oxide (NO_x) Emission Limitations for Combustion Turbines/Duct Burners
- D.2.7 Carbon Monoxide (CO) Emission Limitations for Combustion Turbines/Duct Burners
- D.2.8 Sulfur Dioxide (SO₂) Emission Limitations for Combustion Turbines/Duct Burners
- D.2.9 Volatile Organic Compound Emission Limitations for Combustion Turbines/Duct Burners
- D.2.10 40 CFR 60, Subpart GG (Stationary Gas Turbines)
- D.2.11 40 CFR 60, Subpart Da (Small Electric Utility Steam Generating Units)
- D.2.12 Formaldehyde Limitations
- D.2.13 Ammonia Limitations
- D.2.14 Operational Limitations
- D.2.15 Preventive Maintenance Plan [326 IAC 1-6-3]

Compliance Determination Requirements

- D.2.16 Performance Testing
- D.2.17 40 CFR 60, Subpart GG Compliance Requirements (Stationary Gas Turbines)
- D.2.18 Continuous Emission Monitoring (CEMs)

Record Keeping and Reporting Requirements

- D.2.19 Record Keeping Requirements
- D.2.20 Reporting Requirements

D.3 Natural Gas Conditioning Heaters.....34

Emission Limitations and Standards

- D.3.1 Opacity Limitations
- D.3.2 Best Available Control Technology

Record Keeping and Reporting Requirements

- D.3.3 Record Keeping Requirements
- D.3.4 Reporting Requirements

D.4 Backup Equipment.....35

Emission Limitations and Standards

- D.4.1 BACT Limitation for Fire Pumps
- D.4.2 BACT Limitations for Emergency Generator

Compliance Determination Requirements

- D.4.3 Testing Requirements

Record Keeping and Reporting Requirements

- D.4.4 Record Keeping Requirements
- D.4.5 Reporting Requirements

SECTION A

SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ), and Vigo County Air Pollution Control (VCAPC). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-5.1-3(c)] [326 IAC 2-6.1-4(a)]

The Permittee owns and operates a natural gas merchant power plant.

Authorized Individual:	Plant Manager
Source Address:	5900 Darwin Road, West Terre Haute, IN 47885
Mailing Address:	5900 Darwin Road, West Terre Haute, IN 47885
Phone Number:	(812) 538-2100
SIC Code:	4911
County Location:	Vigo
County Status:	Maintenance Attainment SO ₂ ; Attainment for NO _x , CO, PM ₁₀ , Lead
Source Status:	Major, under PSD rules

A.2 Emissions units and Pollution Control Equipment Summary

This stationary source is approved to construct and operate the following emissions units and pollution control devices:

- (a) Four (4) natural gas-fired combustion turbine generators, designated as units CT11, CT12, CT21, CT22, with a maximum heat input capacity of 1,490.5 MMBtu/hr (per unit on a lower heat heating value), and exhausts to stacks designated as E11B, E12B, E21B and E22B, respectively, for use when operating in simple cycle. During combined cycle operation exhaust goes to stacks designated E11A, E12A, E21A and E22A, respectively.
- (b) Four (4) duct burners, designated as units DB11, DB12, DB21, DB22, with a maximum heat input capacity of 300 MMBtu/hr (per unit on a higher heating value basis) each and exhausts to stacks designated E11A, E12A, E21A, E22A, respectively.
- (c) Four (4) heat recovery steam generators, designated as units HRSG11, HRSG12, HRSG21, HRSG22.
- (d) Four (4) selective catalytic reduction systems, designated as units SCR11, SCR12, SCR21, SCR22.
- (e) Five (5) natural gas conditioning heaters, designated NGCH1, NGCH2, NGCH3, NGCH4, NGCH5 with a maximum heat input capacity of 5 MMBtu/hr (per unit on a higher heating value basis), and exhausts to stacks E7, E8, E9, E10, E11 respectively.

- (f) Two (2) steam turbines, designated as units ST1 and ST2.
- (g) Two (2) cooling towers, designated as units COOL1 and COOL2, exhausts to stacks designated E3 and E4, respectively.
- (h) Two (2) diesel fire pumps, each with a rating of 267 horsepower (hp).
- (i) Two (2) diesel emergency generators, each with a rating of 1,475 horsepower (hp).

A.3 Part 70 Permit Applicability [326 IAC 2-7-2]

This stationary source is required to have a Part 70 permit by 326 IAC 2-7-2 (Applicability) because:

- (a) It is a major source, as defined in 326 IAC 2-7-1(22);
- (b) It is an affected source under Title IV (Acid Deposition Control) of the Clean Air Act, as defined in 326 IAC 2-7-1(3);
- (c) It is a source in a source category designated by the United States Environmental Protection Agency (U.S. EPA) under 40 CFR 70.3 (Part 70 - Applicability).

A.4 Acid Rain Permit Applicability [326 IAC 2-7-2]

This stationary source shall be required to have a Phase II, Acid Rain permit by 40 CFR 72.30 (Applicability) because:

- (a) The combustion turbines are new units under 40 CFR 72.6.
- (b) The source cannot operate the combustion units until their Phase II, Acid Rain permit has been issued.

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1.1 AND 40 CFR 52.780, WITH CONDITIONS LISTED BELOW.

B.1 Permit No Defense [IC 13]

This permit to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

B.2 Definitions

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, any applicable definitions found in IC 13-11, 326 IAC 1-2, and 326 IAC 2-1.1-1 shall prevail.

B.3 Effective Date of the Permit [40 CFR 124]

Pursuant to 40 CFR 124.15, 40 CFR 124.19, and 40 CFR 124.20, this permit is effective immediately after the service of notice of the decision, except as provided in 40 CFR 124. Three (3) days shall be added if service of notice is by mail.

B.4 Revocation of Permits [326 IAC 2-2-8]

Pursuant to 326 IAC 2-2-8(a)(1) and 40 CFR 52.21, this permit to construct shall expire if construction is not commenced within eighteen (18) months after receipt of this approval or if construction is discontinued for a period of eighteen (18) months or more.

B.5 First Time Operation Permit [326 IAC 2-6.1]

This document shall also become a first time operating permit pursuant to 326 IAC 2-5.1-3 when, prior to start of operation, the following requirements are met:

- (a) Any modifications required by 326 IAC 2-1.1 and 326 IAC 2-7-10.5 as a result of a change in the design or operation of emissions units described by this permit have been obtained prior to obtaining an Operation Permit Validation Letter.
- (b) The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section, and Vigo County Air Pollution Control (VCAPC).
 - (1) If the Affidavit of Construction verifies that the facilities covered in this Construction Permit were constructed as proposed in the application, then the facilities may begin operating on the date the Affidavit of Construction is postmarked or hand delivered to IDEM and VCAPC.
 - (2) If the Affidavit of Construction does not verify that the facilities covered in this Construction Permit were constructed as proposed in the application, then the Permittee shall receive an Operation Permit Validation Letter from the Chief of the

Permit Administration & Development Section prior to beginning operation of the facilities.

- (c) If construction is completed in phases; i.e., the entire construction is not done continuously, a separate affidavit must be submitted for each phase of construction. Any permit conditions associated with operation start up dates such as stack testing for New Source Performance Standards (NSPS) shall be applicable to each individual phase.
- (d) Upon receipt of the Operation Permit Validation Letter from the Chief of the Permit Administration & Development Section, the Permittee shall attach it to this document.
- (e) The operation permit will be subject to annual operating permit fees pursuant to 326 IAC 2-7-19 (Fees).
- (f) Pursuant to 326 IAC 2-7-4(a)(1)(A)(ii) and 326 IAC 2-5.1-4, the Permittee shall apply for a Title V operating permit within twelve (12) months of the date on which the source first meets an applicability criterion of 326 IAC 2-7-2.

B.6 Phase Construction Time Frame

Pursuant to 326 IAC 2-1.1-9(5)(Revocation of Permits) and 40 CFR 52.21, IDEM and VCAPC shall revoke this permit to construct if the:

- (a) Construction of Phase 1 has not begun within eighteen (18) months from the effective date of this permit or if during the construction of Phase 1, work is suspended for a continuous period of one (1) year or more.
- (b) Construction of Phase 2 has not begun within eighteen (18) months after the operation of Phase 1 or if during the construction of Phase 2, work is suspended for a continuous period of one (1) year or more.
- (c) Construction of Phase 3 has not begun within eighteen (18) months after the operation of Phase 2 or if during the construction of Phase 3, work is suspended for a continuous period of one (1) year or more.

The OAQ and VCPAC may extend such time upon satisfactory showing that an extension, formally requested by the Permittee is justified.

B.7 BACT Determination for Phase Constructions

Pursuant to 40 CFR 52.21(j)(4), for phase construction projects, the determination of BACT shall be reviewed and modified as appropriate at the latest reasonable time, which occurs no later than eighteen (18) months prior to the scheduled permitted commencement of construction of each independent phase of the project.

B.8 Local Agency Requirement

An application for an operation permit must be made ninety (90) days before start up to:

Vigo County Air Pollution Control

103 South Third Street
Terre Haute, IN 47807

The operation permit issued by Vigo County shall contain as a minimum the conditions in the Operation Conditions section of this permit.

B.9 NSPS Reporting Requirement

Pursuant to the New Source Performance Standards (NSPS), Part 60.7, Part 60.8, the source owner/operator is hereby advised of the requirement to report the following at the appropriate times:

- (a) Commencement of construction date (no later than 30 days after such date);
- (b) Anticipated start-up date (not more than 60 days or less than 30 days prior to such date);
- (c) Actual start-up date (within 15 days after such date); and
- (d) Date of performance testing (at least 30 days prior to such date), when required by a condition elsewhere in this permit.

Reports are to be sent to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue P.O. Box 6015
Indianapolis, IN 46206-6015

And

Vigo County Air Pollution Control
103 South Third Street
Terre Haute, IN 47807

The application and enforcement of these standards have been delegated to the IDEM, OAQ. The requirements of 40 CFR Part 60 are also federally enforceable.

SECTION C SOURCE OPERATION CONDITIONS

Entire Source

C.1 Major Source

Pursuant to 326 IAC 2-2 (Prevention of Significant Deterioration) and 40 CFR 52.21, and 326 IAC 2-7 (Part 70 Permit Program), this source is a major source.

C.2 Preventive Maintenance Plan [326 IAC 1-6-3]

- (a) If required by specific condition(s) in Section D of this permit, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMP) ninety (90) days after the commencement of normal operations after the first construction phase, including the following information on each emissions unit:
 - (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
 - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions;
 - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.
- (b) The Permittee shall implement the Preventive Maintenance Plans as necessary to ensure that failure to implement the Preventive Maintenance Plan does not cause or contribute to a violation of any limitation on emissions or potential to emit.
- (c) PMP's shall be submitted to IDEM, OAQ, and VCAPC upon request and shall be subject to review and approval by IDEM, OAQ, and VCAPC. IDEM, OAQ, and VCAPC may require the Permittee to revise its Preventive Maintenance Plan whenever lack of proper maintenance causes or contributes to any violation.

C.3 Source Modification [326 IAC 2-7-10.5]

- (a) The Permittee must comply with the requirements of 326 IAC 2-7-10.5 whenever the Permittee seeks to construct new emissions units, modify existing emissions units, or otherwise modify the source.
- (b) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

And

Vigo County Air Pollution Control
103 South Third Street
Terre Haute, IN 47807

Any such application should be certified by the "responsible official" as defined by 326 IAC 2-7-1(34) only if a certification is required by the terms of the applicable rule.

C.4 Inspection and Entry [326 IAC 2-5.1-3(e)(4)(B)] [326 IAC 2-6.1-5(a)(4)]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, VCAPC, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a permitted source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) Have access to and copy, at reasonable times, any records that must be kept under this title or the conditions of this permit or any operating permit revisions;
- (c) Inspect, at reasonable times, any processes, emissions units (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit or any operating permit revisions;
- (d) Sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) Utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

C.5 Transfer of Ownership or Operation [326 IAC 2-6.1-6(d)(3)]

Pursuant to [326 IAC 2-6.1-6(d)(3)]

- (a) In the event that ownership of this source is changed, the Permittee shall notify IDEM, OAQ, Permits Branch, and VCAPC, within thirty (30) days of the change.
- (b) The written notification shall be sufficient to transfer the permit to the new owner by an notice-only change pursuant to 326 IAC 2-6.1-6(d)(3).
- (c) IDEM, OAQ, and VCAPC shall issue a revised permit.

The notification which shall be submitted by the Permittee does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1.

C.6 Permit Revocation [326 IAC 2-1-9]

Pursuant to 326 IAC 2-1-9(a)(Revocation of Permits), this permit to construct and operate may be revoked for any of the following causes:

- (a) Violation of any conditions of this permit.
- (b) Failure to disclose all the relevant facts, or misrepresentation in obtaining this permit.
- (c) Changes in regulatory requirements that mandate either a temporary or permanent reduction of discharge of contaminants. However, the amendment of appropriate sections of this permit shall not require revocation of this permit.
- (d) Noncompliance with orders issued pursuant to 326 IAC 1-5 (Episode Alert Levels) to reduce emissions during an air pollution episode.
- (e) For any cause which establishes in the judgment of IDEM and VCAPC, the fact that continuance of this permit is not consistent with purposes of this article.

C.7 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes, sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute non-overlapping integrated averages for a continuous opacity monitor in a six (6) hour period.

C.8 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions). 326 IAC 6-4-2(4) is not federally enforceable.

C.9 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted by using good engineering practices (GEP) pursuant to 326 IAC 1-7-3.

Testing Requirements

C.10 Performance Testing [326 IAC 3-6]

- (a) Compliance testing on new emissions units shall be conducted within 60 days after achieving maximum production rate, but no later than 180 days after initial start-up, if

specified in Section D of this approval. All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue, P. O. Box 6015
Indianapolis, Indiana 46206-6015

And

Vigo County Air Pollution Control
103 South Third Street
Terre Haute, IN 47807

no later than thirty-five (35) days prior to the intended test date. The Permittee shall submit a notice of the actual test date to the above address so that it is received at least two weeks prior to the test date.

- (b) IDEM, OAQ, and VCAPC must receive all test reports within forty-five (45) days after the completion of the testing. IDEM, OAQ, and VCAPC may grant an extension, if the source submits to IDEM, OAQ, a reasonable written explanation within five (5) days prior to the end of the initial forty-five (45) day period.

The documentation submitted by the Permittee does not require certification by the "authorized individual" as defined by 326 IAC 2-1.1-1.

Compliance Monitoring Requirements

C.11 Compliance Monitoring [326 IAC 2-1.1-11]

Compliance with applicable requirements shall be documented as required by this permit. The Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. All monitoring and record keeping requirements not already legally required shall be implemented when operation begins.

C.12 Maintenance of Monitoring Equipment [IC 13-14-1-13]

- (a) In the event that a breakdown of the monitoring equipment occurs, a record shall be made of the times and reasons of the breakdown and efforts made to correct the problem. To the extent practicable, supplemental or intermittent monitoring of the parameter should be implemented at intervals no less frequent than required in Section D of this permit until such time as the monitoring equipment is back in operation. In the case of continuous monitoring, supplemental or intermittent monitoring of the parameter should be implemented at intervals no less than one (1) hour until such time as the continuous

monitor is back in operation.

- (b) The Permittee shall install, calibrate, quality assure, maintain, and operate all necessary monitors and related equipment. In addition, prompt corrective action shall be initiated whenever indicated.

C.13 Monitoring Methods [326 IAC 3]

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, or other approved methods as specified in this permit.

C.14 Compliance Monitoring Plan - Failure to Take Response Steps [326 IAC 1-6] [326 IAC 2-2-4]

- (a) The Permittee is required to implement a compliance monitoring plan to ensure that reasonable information is available to evaluate its continuous compliance with applicable requirements. This compliance monitoring plan is comprised of:
 - (1) This condition;
 - (2) The Compliance Determination Requirements in Section D of this permit;
 - (3) The Compliance Monitoring Requirements in Section D of this permit;
 - (4) The Record Keeping and Reporting Requirements in Section C (Monitoring Data Availability, General Record Keeping Requirements, and General Reporting Requirements) and in Section D of this permit; and
 - (5) A Compliance Response Plan (CRP) for each compliance monitoring condition of this permit. CRP's shall be submitted to IDEM, OAQ, and VCAPC upon request and shall be subject to review and approval by IDEM, OAQ, and VCAPC. The CRP shall be prepared within ninety (90) days after the commencement of normal operation after the first phase of construction and shall be maintained on site, and is comprised of:
 - (A) Response steps that will be implemented in the event that compliance related information indicates that a response step is needed pursuant to the requirements of Section D of this permit; and
 - (B) A time schedule for taking such response steps including a schedule for devising additional response steps for situations that may not have been predicted.
- (b) For each compliance monitoring condition of this permit, appropriate response steps shall be taken when indicated by the provisions of that compliance monitoring condition. Failure to perform the actions detailed in the compliance monitoring conditions or failure to take the response steps within the time prescribed in the Compliance Response Plan, shall constitute a violation of the permit unless taking the response steps set forth in the Compliance Response Plan would be unreasonable.

- (c) After investigating the reason for the excursion, the Permittee is excused from taking further response steps for any of the following reasons:
 - (1) The monitoring equipment malfunctioned, giving a false reading. This shall be an excuse from taking further response steps providing that prompt action was taken to correct the monitoring equipment.
 - (2) The Permittee has determined that the compliance monitoring parameters established in the permit conditions are technically inappropriate, has previously submitted a request for an administrative amendment to the permit, and such request has not been denied or;
 - (3) An automatic measurement was taken when the process was not operating; or
 - (4) The process has already returned to operating within "normal" parameters and no response steps are required.
- (d) Records shall be kept of all instances in which the compliance related information was not met and of all response steps taken.

C.15 Actions Related to Noncompliance Demonstrated by a Stack Test

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall take appropriate corrective actions. The Permittee shall submit a description of these corrective actions to IDEM, OAQ, and VCAPC within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize emissions from the affected emissions unit while the corrective actions are being implemented. IDEM, OAQ, and VCAPC shall notify the Permittee within thirty (30) days, if the corrective actions taken are deficient. The Permittee shall submit a description of additional corrective actions taken to IDEM, OAQ, and VCAPC within thirty (30) days of receipt of the notice of deficiency. IDEM, OAQ and VCPAC reserve the authority to use enforcement activities to resolve noncompliant stack tests.
- (b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAQ, and VCAPC that retesting in one hundred and twenty (120) days is not practicable, IDEM, OAQ and VCAPC may extend the retesting deadline. Failure of the second test to demonstrate compliance with the appropriate permit conditions may be grounds for immediate revocation of the permit to operate the affected emissions unit.

The documents submitted pursuant to this condition do not require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1.

Record Keeping and Reporting Requirements

C.16 Malfunctions Report [326 IAC 1-6-2]

Pursuant to 326 IAC 1-6-2 (Records; Notice of Malfunction):

- (a) A record of all malfunctions, including startups or shutdowns of any facility or emission control equipment, which result in violations of applicable air pollution control regulations or applicable emission limitations shall be kept and retained for a period of three (3) years and shall be made available to the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ), Vigo County Air Pollution Control (VCAPC), or appointed representative upon request.
- (b) When a malfunction of any facility or emission control equipment occurs which lasts more than one (1) hour, said condition shall be reported to OAQ and VCAPC, using the Malfunction Report Forms (2 pages). Notification shall be made by telephone or facsimile, as soon as practicable, but in no event later than four (4) daytime business hours after the beginning of said occurrence.

- (c) Failure to report a malfunction of any emission control equipment shall constitute a violation of 326 IAC 1-6, and any other applicable rules. Information of the scope and expected duration of the malfunction shall be provided, including the items specified in 326 IAC 1-6-2(a)(1) through (6).
- (d) Malfunction is defined as any sudden, unavoidable failure of any air pollution control equipment, process, or combustion or process equipment to operate in a normal and usual manner. [326 IAC 1-2-39]

C.17 Monitoring Data Availability [326 IAC 2-6.1-2] [IC 13-14-1-13]

- (a) With the exception of performance tests conducted in accordance with Section C- Performance Testing, all observations, sampling, maintenance procedures, and record keeping, required as a condition of this permit shall be performed at all times the equipment is operating at normal representative conditions.
- (b) As an alternative to the observations, sampling, maintenance procedures, and record keeping of subsection (a) above, when the equipment listed in Section D of this permit is not operating, the Permittee shall either record the fact that the equipment is shut down or perform the observations, sampling, maintenance procedures, and record keeping that would otherwise be required by this permit.
- (c) If the equipment is operating but abnormal conditions prevail, additional observations and sampling should be taken with a record made of the nature of the abnormality.
- (d) If for reasons beyond its control, the operator fails to make required observations, sampling, maintenance procedures, or record keeping, reasons for this must be recorded.
- (e) At its discretion, IDEM and VCAPC may excuse such failure providing adequate justification is documented and such failures do not exceed five percent (5%) of the operating time in any quarter.
- (f) Temporary, unscheduled unavailability of staff qualified to perform the required observations, sampling, maintenance procedures, or record keeping shall be considered a valid reason for failure to perform the requirements stated in (a) above.

C.18 General Record Keeping Requirements [326 IAC 2-6.1-2]

- (a) Records of all required monitoring data and support information shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be kept at the source location for a minimum of three (3) years and available upon the request of an IDEM, OAQ, and VCAPC representative. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner or Vigo County Air Pollution Control makes a written request for records to the Permittee, the Permittee shall furnish the records to the Commissioner or Vigo County Air Pollution Control within a reasonable time.
- (b) Records of required monitoring information shall include, where applicable:

- (1) The date, place, and time of sampling or measurements;
 - (2) The dates analyses were performed;
 - (3) The company or entity performing the analyses;
 - (4) The analytic techniques or methods used;
 - (5) The results of such analyses; and
 - (6) The operating conditions existing at the time of sampling or measurement.
- (c) Support information shall include, where applicable:
- (1) Copies of all reports required by this permit;
 - (2) All original strip chart recordings for continuous monitoring instrumentation;
 - (3) All calibration and maintenance records;
 - (4) Records of preventive maintenance shall be sufficient to demonstrate that failure to implement the Preventive Maintenance Plan did not cause or contribute to a violation of any limitation on emissions or potential to emit. To be relied upon subsequent to any such violation, these records may include, but are not limited to: work orders, parts inventories, and operator's standard operating procedures. Records of response steps taken shall indicate whether the response steps were performed in accordance with the Compliance Response Plan required by Section C - Compliance Monitoring Plan - Failure to take Response Steps, of this permit, and whether a deviation from a permit condition was reported. All records shall briefly describe what maintenance and response steps were taken and indicate who performed the tasks.
- (d) All record keeping requirements not already legally required shall be implemented when operation begins.

C.19 General Reporting Requirements [326 IAC 2-1.1-11] [326 IAC 2-6.1-2] [IC 13-14-1-13]

- (a) To affirm that the source has met all the compliance monitoring requirements stated in this permit the source shall submit a Semi-annual Compliance Monitoring Report. Any deviation from the requirements and the date(s) of each deviation must be reported. The Compliance Monitoring Report shall include the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (b) The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue, P. O. Box 6015

Indianapolis, Indiana 46206-6015

And

Vigo County Air Pollution Control
103 South Third Street
Terre Haute, IN 47807

- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, and VCAPC on or before the date it is due.
- (d) Unless otherwise specified in this permit, any semi-annual report shall be submitted within thirty (30) days of the end of the reporting period. The reports require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (e) All instances of deviations must be clearly identified in such reports. A reportable deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit or a rule. It does not include:
 - (1) An excursion from compliance monitoring parameters as identified in Section D of this permit unless tied to an applicable rule or limit; or
 - (2) A malfunction as described in 326 IAC 1-6-2; or
 - (3) Failure to implement elements of the Preventive Maintenance Plan unless lack of maintenance has caused or contributed to a deviation.
 - (4) Failure to make or record information required by the compliance monitoring provisions of Section D unless such failure exceeds 5% of the required data in any calendar quarter.

A Permittee's failure to take the appropriate response step when an excursion of a compliance monitoring parameter has occurred or failure to monitor or record the required compliance monitoring is a deviation.
- (f) Any corrective actions or response steps taken as a result of each deviation must be clearly identified in such reports.
- (g) The first report shall cover the period commencing on the date start of normal operation after the first phase of construction and ending on the last day of the reporting period.

Mirant Sugar Creek LLC
West Terre Haute, Indiana
Permit Reviewer: David Howard

First Notice Only Change No: 167-15906
Change by: Janet Mobley

Page 20 of 47
CP-165-10476
ID-165-00022

SECTION D.1 FACILITY CONDITIONS – Simple Cycle Operation

Four (4) natural gas-fired combustion turbines designated as units CT11, CT12, CT21, CT22, with a maximum heat input capacity of 1,490.5 MMBtu/hr (per unit on a lower heating value basis), and exhausts to stacks designated as E11B, E12B, E21B and E22B, respectively, for use when operating in simple cycle.

(The information describing the process contained in this facility description box is descriptive information, and does not constitute enforceable conditions.)

Emission Limitations and Standards

D.1.1 Prevention of Significant Deterioration [326 IAC 2-2]

Pursuant to 326 IAC 2-2 (PSD), this new source is subject to the requirements of 326 IAC 2-2 (Prevention of Significant Deterioration) for emissions of PM, PM₁₀, SO₂, CO, NO_x, and VOC because the potential to emit for these pollutants exceed the PSD major significant thresholds. Therefore, the PSD provisions require that this new source be reviewed to ensure compliance with the National Ambient Air Quality Standards (NAAQS), the applicable PSD air quality increments, and the requirements to apply the Best Available Control Technology (BACT) for the affected pollutants.

D.1.2 Particulate Matter (PM and PM₁₀) Emission Limitations for Combustion Turbines

Pursuant to 326 IAC 2-2 (PSD Requirements) the total PM, is the sum of filterable PM, and PM₁₀ (filterable and condensable), emissions from each combustion turbine stack shall not exceed 0.012 pounds per MMBtu on a lower heating value basis, which is equivalent to eighteen (18) pounds per hour for each combustion turbine.

D.1.3 Opacity Limitations

Pursuant to 326 IAC 2-2 (PSD Requirements) the opacity from each associated combustion turbine stack shall not exceed twenty (20) percent (6-minute average), except for one 6-minute period per hour of not more than 27 percent. The opacity standards apply at all times, except during periods of startup, shutdown or malfunction. This satisfies the opacity limitations required by 326 IAC 5-1 (Opacity Limitations).

D.1.4 Startup and Shutdown Limitations for Combustion Turbines

Pursuant to 326 IAC 2-2 (PSD Requirements), a startup or shutdown is defined as operation less than fifty (50) percent load. Each combustion turbine-generating unit shall comply with the following:

- (a) A startup or shutdown period shall not exceed two (2) hours. Each turbine shall not exceed 250 hours per year for startups and 42 hours per year for shutdowns.
- (b) The NO_x emissions from each combustion turbine stack shall not exceed 32.5 tons per year for startup and shutdown emissions. Each combustion turbine shall not exceed 472 pounds of NO_x per startup and 284 pounds of NO_x per shutdown.

- (c) The CO emissions from each combustion turbine stack shall not 41.3 tons per year for startup and shutdown emissions. Each combustion turbine shall not exceed 600 pounds of CO per startup and 360 pounds of CO per shutdown.

D.1.5 Nitrogen Oxides (NO_x) Emission Limitations for Combustion Turbines

- (a) Pursuant to 326 IAC 2-2 (PSD Requirements) each combustion turbine generating unit shall comply with the following, excluding startup and shutdown:
 - (1) During normal simple cycle operation (fifty (50) percent load or more), the NO_x emissions from each combustion turbine shall not exceed 9.0 ppmvd corrected to fifteen (15) percent oxygen, based on a three (3) hour averaging period, which is equivalent to 54.0 pounds per hour for each combustion turbine.
 - (2) Each combustion turbine shall be equipped with dry low-NO_x combustors and operated using good combustion practices to control NO_x emissions.
 - (3) Use natural gas as the only fuel.
- (b) Pursuant to 326 IAC 2-2 (PSD Requirements), the annual NO_x emission from each of the four (4) combustion turbines, excluding startup and shutdown emissions, shall not exceed 236.52 tons per year.

D.1.6 Carbon Monoxide (CO) Emission Limitations for Combustion Turbines

- (a) Pursuant to 326 IAC 2-2 (PSD Requirements), each combustion turbine shall comply with the following, excluding startup and shutdown:
 - (1) During normal simple cycle operation (fifty (50) percent load or more), the CO emissions from each combustion turbine shall not exceed 9 ppmvd corrected to fifteen (15) percent oxygen, based on a 24 hour averaging period, which is equivalent to 26.4 pounds per hour from each combustion turbine.
 - (2) Good combustion practices shall be applied to minimize CO emissions.
 - (3) Use natural gas as the only fuel.
- (b) Pursuant to 326 IAC 2-2 (PSD Requirements), the annual CO emission from each of the four (4) combustion turbines, excluding startup and shutdown emissions, shall not exceed 115.63 tons per year.

D.1.7 Sulfur Dioxide (SO₂) Emission Limitations for Combustion Turbines

- Pursuant to 326 IAC 2-2 (PSD Requirements), each combustion turbine shall comply with the following, excluding startup and shutdown:
- (1) During normal simple cycle operation (fifty (50) percent load or more), the SO₂ emissions from each combustion turbine shall not exceed 0.0028 pounds per MMBtu on a lower heating values basis, which is equivalent to 4.2 pounds per hour from each

combustion turbine.

- (2) The use of low sulfur natural gas as the only fuel for the four (4) combustion turbines. The sulfur content of the natural gas shall not exceed 0.007 percent by weight (two (2) grains per 100 scf)
- (3) Perform good combustion practices.

D.1.8 Volatile Organic Compound (VOC) Emission Limitations for Combustion Turbines

Pursuant to 326 IAC 8-1-6 (VOC BACT Requirements), the following requirements must be met, excluding startup and shutdown:

- (1) The VOC emissions from each combustion turbine shall not exceed 0.0024 pounds per MMBtu on a lower heating value basis, which is equivalent to 3.7 pounds VOC per hour for each combustion turbine.
- (2) The use of natural gas as the only fuel
- (3) Good combustion practice shall be implemented to minimize VOC emissions.

D.1.9 40 CFR 60, Subpart GG (Stationary Gas Turbines)

The four (4) natural gas combustion turbines are subject to 40 CFR Part 60, Subpart GG (Stationary Gas Turbines) because the heat input at peak load is equal to or greater than 10.7 gigajoules per hour (10 MMBtu per hour), based on the lower heating value of the fuel fired.

Pursuant to 326 IAC 12-1 and 40 CFR 60, Subpart GG (Stationary Gas Turbines), the Permittee shall:

- (1) Limit nitrogen oxides emissions from the natural gas turbines to 0.0113% by volume at 15% oxygen on a dry basis, as required by 40 CFR 60.332, to:

$$STD = 0.0075 \frac{(14.4)}{Y} + F,$$

where STD = allowable NO_x emissions (percent by volume at 15 percent oxygen on a dry basis).

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt-hour.

F = NO_x emission allowance for fuel-bound nitrogen as defined in paragraph (a)(3) of 40 CFR 60.332.

- (2) Limit sulfur dioxide emissions, as required by 40 CFR 60.333, to 0.015 percent by volume at 15 percent oxygen on a dry basis, or use natural gas fuel with a sulfur content less than or equal to 0.8 percent by weight; Compliance with Condition D.1.7 constitutes compliance with this requirement.

D.1.10 Formaldehyde Limitations

Pursuant to 326 IAC 2-1.1-5 (Air Quality Requirements), the formaldehyde emissions from each combustion turbine stack shall not exceed 0.00036 pounds of formaldehyde per MMBtu on a lower heating value basis.

D.1.11 Operational Limitation

Pursuant to 326 IAC 2-2 (PSD Requirements), conditions contained within this section of the permit (D.1 Simple Cycle Operation) shall be followed (per turbine) when combustion turbine exhaust is routed through the integral bypass stack designated as E11B, E12B, E21B, and E22B. During periods when turbine exhaust is not routed through the integral bypass stacks (E11B, E12B, E21B, and E22B), the Permittee shall follow the conditions contained in Section D.2 Combined Cycle Operation.

D.1.12 Preventive Maintenance Plan [326 IAC 1-6-3]

A Preventive Maintenance Plan, in accordance with Section C - Preventive Maintenance Plan, of this permit, is required for each combustion turbine.

Compliance Determination Requirements

D.1.13 Performance Testing

- (a) Pursuant to 326 IAC 3-5 the Permittee shall conduct a performance test, not later than one-hundred and eighty days (180) after a facility startup or monitor installation, on the combustion turbine exhaust stacks (E11B, E12B, E21B, and E22B) in order to certify continuous emission monitoring systems for NO_x and CO.
- (b) Within sixty (60) days after initial startup, but no later than one-hundred and eighty (180) days after initial startup, the Permittee shall perform formaldehyde test for each combustion turbine stack (E11B, E12B, E21B, and E22B) utilizing methods approved by the Commissioner when operating 60%, 75%, and 100% load. These tests shall be performed in accordance with Section C – Performance Testing, in order to verify the formaldehyde emission factor as specified in Condition D.1.10.
- (c) Within sixty (60) days after initial startup, but no later than one-hundred and eighty (180) days after initial startup, the Permittee shall perform NO_x and CO stack tests for each turbine (stacks designated as E11B, E12B, E21B, and E22B) during a startup/shutdown period, utilizing methods as approved by the Commissioner. These tests shall be performed in accordance with Section C – Performance Testing, in order to document compliance with Condition D.1.4.
- (d) Within sixty (60) days after achieving maximum production rate, but no later than one-hundred and eighty (180) days after initial startup, the Permittee shall conduct NO_x and SO₂ stack tests for each turbine utilizing methods approved by the Commissioner. These tests shall be performed in accordance with 40 CFR 60.335 and Section C – Performance Testing, in order to document compliance with Condition D.1.9.
- (e) Within sixty (60) days after initial startup, but no later than one-hundred eighty (180) after initial startup, the Permittee shall perform PM, PM₁₀ (filterable and condensable), and VOC stack tests for each combustion turbine stack (E11B, E12B, E21B, and E22B) utilizing methods approved by the Commissioner. These test shall be performed in accordance with Section C –

Performance Testing, in order to document compliance with Condition D.1.2 and D.1.8(1).

- (f) IDEM, OAQ and VCAPC retain the authority under 326 IAC 2-1-4(f) to require the Permittee to perform additional and future compliance testing as necessary.

D.1.14 40 CFR Part 60, Subpart GG Compliance Requirements (Stationary Gas Turbines)

Pursuant to 40 CFR Part 60, Subpart GG (Stationary Gas Turbines), the Permittee shall monitor the nitrogen and sulfur content of the natural gas on a monthly basis as follows:

- (a) Determine compliance with the nitrogen oxide and sulfur dioxide standards in 40 CFR 60.332 and 60.333(a), per requirements described in 40 CFR 60.335(c);
- (b) Determine the sulfur content of the natural gas being fired in the turbine by ASTM Methods D 1072-80, D 3030-81, D 4084-82, or D 3246-81. The applicable ranges of some ASTM methods mentioned are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Administrator; and
- (c) Determine the nitrogen content of the natural gas being fired in the turbine by using analytical methods and procedures that are accurate to within 5 percent and are approved by the Administrator.

The analyses required above may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor or any other qualified agency.

Owners, operators or fuel vendors may develop custom fuel schedules for determination of the nitrogen and sulfur content based on the design and operation of the affected facility and the characteristics of the fuel supply. These schedules shall be substantiated with data and must be approved by the Administrator before they can be used to comply with the above requirements.

D.1.15 Continuous Emission Monitoring

- (a) The owner or operator of a new source with an emission limitation or permit requirement established under 326 IAC 2-5.1-3 and 326 IAC 2-2, shall be required to install a continuous emissions monitoring system or alternative monitoring plan as allowed under the Clean Air Act and 326 IAC 3-5-1(d).
- (b) The Permittee shall install, calibrate, certify, operate and maintain a continuous emissions monitoring system for each combustion turbine stack for NO_x, CO, and O₂ (E11B, E12B, E21B and E22B) in accordance with 326 IAC 3-5-2 and 3-5-3.
 - (1) The continuous emission monitoring system (CEMS) shall measure NO_x and CO emissions rates in pounds per hour, uncorrected parts per million, and parts per million on a dry volume basis (ppmvd) corrected to 15% O₂. The use of CEMS to measure and record the NO_x and CO hourly limits, is sufficient to demonstrate compliance with the limitations established in the BACT analysis and set forth in the permit. To demonstrate compliance with the NO_x limit, the source shall take an average of the ppmvd corrected

to 15% O₂ over a three (3) hour averaging period. To demonstrate compliance with the CO limit, the source shall take an average of the ppmvd corrected to 15% O₂ over a twenty four (24) hour averaging period. The source shall maintain records of the ppmvd corrected to 15% O₂ and the pounds per hour.

- (2) The Permittee shall determine compliance with Conditions D.1.4 utilizing data from the NO_x, CO, and O₂ CEMS, the fuel flow meter, and Method 19 calculations.
- (3) The Permittee shall submit to IDEM, OAQ, and VCAPC within ninety (90) days after monitor installation, a complete written continuous monitoring standard operating procedure (SOP), in accordance with the requirements of 326 IAC 3-5-4.
- (4) The Permittee shall record the output of the system and shall perform the required record keeping, pursuant to 326 IAC 3-5-6, and reporting, pursuant to 326 IAC 3-5-7.

Record Keeping and Reporting Requirements [326 IAC 2-5.1-3(e)(2)] [326 IAC 2-6.1-5(a)(2)]

D.1.16 Record Keeping Requirements

- (a) To document compliance with Condition D.1.2, D.1.5 through D.1.9, and D.1.11, the Permittee shall maintain records of the following:
 - (1) Amount of natural gas combusted (in MMCF) per turbine during each month
 - (2) The percent sulfur content of the natural gas
 - (3) The average heat input, on a lower heating value basis, of each turbine on a 30-day rolling average.
- (b) To document compliance with Condition D.1.4, the Permittee shall maintain records of the following:
 - (1) The type of operation (i.e., startup or shutdown) with supporting operational data
 - (2) The total number of minutes for startup or shutdown per 24-hour period per turbine
 - (3) The CEMS data, fuel flow meter data, and Method 19 calculations corresponding to each startup and shutdown period.
- (c) To document compliance with Conditions D.1.5 and D.1.6, the Permittee shall maintain records of the emission rates of NO_x and CO in pounds per hour and ppmvd corrected to 15% oxygen.
- (d) To document compliance with Condition D.1.15, the Permittee shall maintain records, including raw data of all monitoring data and supporting information, for a minimum of five (5) years from the date as described in 326 IAC 3-5-7(a). The records shall include the information described in 326 IAC 3-5-7(b).
- (e) To document compliance with Condition D.1.9, the source shall maintain records of the natural

gas analyses, including the sulfur and nitrogen content of the gas, for a period of three (3) years.

- (f) A record of the hours of operation per year per turbine for simple cycle operation shall be maintained.
- (g) All records shall be maintained in accordance with Section C – General Record Keeping Requirements, of this permit

D.1.17 Reporting Requirements

The Permittee shall submit the following information on a quarterly basis:

- (a) Records of excess NO_x and CO emissions (defined in 326 IAC 3-5-7 and 40 CFR Part 60.7) from the continuous emissions monitoring system for each parameter described in Condition D.1.15. These reports shall be submitted within thirty (30) calendar days following the end of each calendar quarter and in accordance with Section C – General Reporting Requirements of this permit.
- (b) The Permittee shall report periods of excess emissions, as required by 40 CFR 60.334(c)
- (c) A quarterly summary of the CEMs data to document compliance with D.1.5(a)(1) and D.1.6(a)(1) shall be submitted to the address listed in Section C – General Reporting Requirements, of this permit, within thirty (30) days after the end of the quarter being reported.
- (d) A quarterly summary of the total number of startup and shutdown hours of operation and emissions corresponding to startup and shutdown to document compliance with Condition D.1.4, shall be submitted to the address listed in Section C – General Reporting Requirements, of this permit, within thirty (30) days after the end of the quarter being reported.

SECTION D.2 FACILITY CONDITIONS – Combined Cycle Operation

- (a) Four (4) natural gas-fired combustion turbines, designated as units CT11, CT12, CT21, CT22, with a maximum heat input capacity of 1,490.5 MMBtu/hr (per unit on a lower heating value basis), and exhausts to stacks designated as E11B, E12B, E21B and E22B, respectively, for use when operating in simple cycle. During combined cycle operation exhaust goes to stacks designated E11A, E12A, E21A and E22A, respectively.
- (b) Four (4) duct burners, designated as units DB11, DB12, DB21, DB22, with a maximum heat input capacity of 300 MMBtu/hr (per unit on a higher heating value basis) each and exhausts to stacks designated E11A, E12A, E21A, E22A, respectively.
- (c) Four (4) heat recovery steam generators, designated as units HRSG11, HRSG12, HRSG21, HRSG22.
- (d) Four (4) selective catalytic reduction systems, designated as units SCR11, SCR12, SCR21, SCR22.
- (e) Two (2) cooling towers, designated as units COOL1 and COOL2, exhausts to stacks designated E3 and E4, respectively.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards

D.2.1 Prevention of Significant Deterioration [326 IAC 2-2]

Pursuant to 326 IAC 2-2 (PSD), this new source is subject to the requirements of 326 IAC 2-2 (Prevention of Significant Deterioration) for emissions of PM, PM₁₀, SO₂, CO, NO_x, and VOC because the potential to emit for these pollutants exceed the PSD major significant thresholds. Therefore, the PSD provisions require that this new source be reviewed to ensure compliance with the National Ambient Air Quality Standards (NAAQS), the applicable PSD air quality increments, and the requirements to apply the Best Available Control Technology (BACT) for the affected pollutants.

D.2.2 Particulate Matter (PM/PM₁₀) Emission Limitations for Combustion Turbines/Duct Burners

- (a) Pursuant to 326 IAC 2-2 (PSD Requirements), the total PM is the sum of PM (filterable) and PM₁₀ (filterable and condensable), emissions from each combustion turbine shall not exceed 0.012 pounds per MMBtu (on a lower heating value basis) which is equivalent to eighteen (18) pounds per hour for each combustion turbine.
- (b) Pursuant to 326 IAC 2-2 (PSD Requirements), the total PM, sum of PM (filterable) and PM₁₀ (filterable and condensable), emissions from each duct burner shall not exceed 0.0075 pounds per MMBtu on a higher heating value basis, which is equivalent to 2.2 pounds per hour.

- (c) Pursuant to 326 IAC 2-2 (PSD Requirements), the total PM is the sum of PM (filterable) and PM₁₀ (filterable and condensable), emissions from each combustion turbine when its associated duct burner is operating, shall not exceed 20.2 pounds per hour for each combustion turbine and duct burner.

D.2.3 Opacity Limitations

Pursuant to 326 IAC 2-2 (PSD Requirements) the opacity from each associated combustion turbine stack shall not exceed twenty (20) percent (6-minute average), except for one 6-minute period per hour of not more than 27 percent. The opacity standards apply at all times, except during periods of startup, shutdown or malfunction. This satisfies the opacity limitations required by 326 IAC 5-1 (Opacity Limitations).

D.2.4 Particulate Matter Emissions (PM/PM₁₀) for Cooling Towers

Pursuant to 326 IAC 2-2 (PSD Requirements) each cooling tower shall comply with the following:

- (1) PM emissions shall not exceed 1.41 pounds per hour, and
- (2) Employ good design and operation practices to limit emissions from the cooling towers.
- (3) For compliance purposes, cooling tower PM emissions shall be calculated using emission factors from USEPA AP-42 Section 13.4.

D.2.5 Startup and Shutdown Limitations for Combustion Turbines

Pursuant to 326 IAC 2-2 (PSD Requirements), a startup or shutdown is defined as less than fifty (50) percent load. Each combustion turbine generating unit shall comply with the following:

- (a) Each startup or shutdown period shall not exceed four (4) hours. Each turbine shall not exceed 500 hours per year for startups and 83 hours per year for shutdowns.
- (b) The NO_x emissions from each combustion turbine stack shall not exceed 64.9 tons per year for startup and shutdown emissions. Each combustion turbine shall not exceed 80 ppmvd corrected to 15% O₂ during startup, and 48 ppmvd corrected to 15% O₂ shutdown, averaged over the duration of the startup or shutdown.
- (c) The CO emissions from each combustion turbine stack shall not exceed 82.5 tons per year for startup and shutdown emissions. Each combustion turbine shall not exceed 150 ppmvd corrected to 15% O₂ during startup, and 90 ppmvd corrected to 15% O₂ shutdown, averaged over the duration of the startup or shutdown.

D.2.6 Nitrogen Oxides (NO_x) Emission Limitations for Combustion Turbines/Duct Burners

- (a) Pursuant to 326 IAC 2-2 (PSD Requirements) each combustion turbine/steam generating unit shall comply with the following, excluding startup and shutdown:
 - (1) During normal combined cycle operation (fifty (50) percent load or more), the NO_x emissions from each combustion turbine stack shall not exceed 3.0 ppmvd corrected to fifteen (15) percent oxygen, based on a three (3) hour averaging period, which is

equivalent to 17.89 pounds per hour for each combustion turbine.

- (2) During normal combined cycle operation (fifty (50) percent load or more), the NO_x emissions from each combustion turbine stack, when its associated duct burner is operating, shall not exceed 3.0 ppmvd corrected to fifteen (15) percent oxygen, based on a three (3) hour averaging period, which is equivalent to 18 pounds per hour for each combustion turbine and duct burner.
 - (3) The duct burners shall not be operated until normal operation begins.
 - (4) Each combustion turbine shall be equipped with dry low-NO_x burners and operated using good combustion practices to control NO_x emissions.
 - (5) A selective catalytic reduction (SCR) system shall be installed and operated at all times, except during periods of startup and shutdown, to control NO_x emissions.
 - (6) Use natural gas as the only fuel.
- (b) Pursuant to 326 IAC 2-2 (PSD Requirements), the annual NO_x emission from each of the four (4) combustion turbines and associated duct burners, excluding startup and shutdown emissions, shall not exceed 78.36 tons per year.

D.2.7 Carbon Monoxide (CO) Emission Limitations for Combustion Turbines/Duct Burners

- (a) Pursuant to 326 IAC 2-2 (PSD Requirements), each steam generating unit shall comply with the following, excluding startup and shutdown:
 - (1) During normal combined cycle operation (fifty (50) percent load or more), the CO emissions from each combustion turbine shall not exceed 9 ppmvd corrected to 15% O₂ on a 24 hour averaging period, which is equivalent to 26.4 pounds per hour for each combustion turbine.
 - (2) During normal operation (fifty (50) percent load or more), the CO emissions from each combustion turbine stack, when its associated duct burner is operating, shall not exceed 14 ppmvd corrected to 15% O₂ on a 24 hour averaging period, which is equivalent to 51.0 pounds per hour for each combustion turbine and duct burner.
 - (3) The duct burners shall not be operated until normal operation begins.
 - (4) Good combustion practices shall be applied to minimize CO emissions.
 - (5) Use natural gas as the only fuel
- (b) Pursuant to 326 IAC 2-2 (PSD Requirements), the annual NO_x emission from each of the four (4) combustion turbines and associated duct burners, excluding startup and shutdown emissions, shall not exceed 131.86 tons per year.

D.2.8 Sulfur Dioxide (SO₂) Emission Limitations for Combustion Turbines/Duct Burners

Pursuant to 326 IAC 2-2 (PSD Requirements), each combustion turbine and duct burner shall comply with the following, excluding startup and shutdown:

- (1) During normal combined cycle operation (fifty (50) percent load or more), the SO₂ emissions from each combustion turbine shall not exceed 0.0028 pounds per MMBtu on a lower heating value basis, which is equivalent to 4.2 pounds per hour for each combustion turbine.
- (2) During normal operation of each duct burner, the SO₂ emissions shall not exceed 0.001 pounds per MMBtu on a higher heating value basis, which is equivalent to 0.2 pounds per hour for each combustion turbine.
- (3) During normal combined cycle operation of each combustion turbine when its associated duct burner is operating, the SO₂ emissions from each turbine stack shall 4.4 pounds per hour.
- (4) The use of low sulfur natural gas as the only fuel for the combustion turbines and duct burners. The sulfur content of the natural gas shall not exceed 0.007 percent by weight (two (2) grains per 100 scf).
- (5) Perform good combustion practice.

D.2.9 Volatile Organic Compound (VOC) Emission Limitations for Combustion Turbines/Duct Burners

Pursuant to 326 IAC 8-1-6 (VOC Requirements) and 326 2-2 (PSD Requirements), the following requirements must be met, excluding startup and shutdown:

- (1) The VOC emissions from each combustion turbine shall not exceed 0.0025 pounds per MMBtu on a lower heating value basis, which is equivalent to 3.7 pounds VOC per hour for each combustion turbine.
- (2) The VOC emissions from each duct burner shall not exceed 0.005 pounds per MMBtu on a higher heating value basis, which is equivalent to 1.6 pounds VOC per hour.
- (3) The VOC emissions from each combustion turbine stack, when its associated duct burner is operating shall not 5.3 pounds of VOC per hour.
- (4) The use of natural gas as the only fuel.
- (5) Good combustion practice shall be implemented to minimize VOC emissions.

D.2.10 40 CFR 60, Subpart GG (Stationary Gas Turbines)

The four (4) natural gas combustion turbines are subject to 40 CFR Part 60, Subpart GG (Stationary Gas Turbines) because the heat input at peak load is equal to or greater than 10.7 gigajoules per hour (10 MMBtu per hour), based on the lower heating value of the fuel fired.

Pursuant to 326 IAC 12-1 and 40 CFR 60, Subpart GG (Stationary Gas Turbines), the Permittee shall:

- (1) Limit nitrogen oxides emissions from the natural gas turbines to 0.0113% by volume at 15% oxygen on a dry basis, as required by 40 CFR 60.332, to:

$$\text{STD} = 0.0075 \frac{(14.4)}{Y} + F,$$

where STD = allowable NO_x emissions (percent by volume at 15 percent oxygen on a dry basis).

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt-hour.

F = NO_x emission allowance for fuel-bound nitrogen as defined in paragraph (a)(3) of 40 CFR 60.332.

- (2) Limit sulfur dioxide emissions, as required by 40 CFR 60.333, to 0.015 percent by volume at 15 percent oxygen on a dry basis, or use natural gas fuel with a sulfur content less than or equal to 0.8 percent by weight; Compliance with Condition D.2.8 constitutes compliance with this condition.

D.2.11 40 CFR Part 60, Subpart Da (Electric Utility Steam Generating Units)

The heat recovery steam generator (HRSG) duct burners (DB) are subject to 40 CFR Part 60, Subpart Da because the heat input capacity is greater than 250 MMBtu/hr on a higher heating value basis.

Pursuant to 40 CFR Part 60, Subpart Da, the Permittee shall:

- (a) The opacity from each combustion turbine stack, when its associated duct burner is operating, shall not exceed twenty (20) percent (6-minute average), except for on 6-minute period per hour of not more than 27 percent. The opacity standards apply at all times, except during periods of startup, shutdown or malfunction. This satisfies the opacity limitations required by 326 IAC 5-1 (Opacity Limitations).
- (b) The PM emissions from each duct burner shall not exceed 0.03 pounds per MMBtu heat input on a higher heating value basis. Compliance with Condition D.2.2 constitutes compliance with this condition.
- (c) Each duct burner shall not exceed 1.6 lb/MW-hr NO_x, on a thirty (30) day rolling average.
- (d) Each duct burner shall not exceed 0.20 pounds SO₂ per MMBtu heat input, determined on a 30-day rolling average basis. Compliance with condition D.2.8 constitutes compliance with this condition.

D.2.12 Formaldehyde Limitations

Pursuant to 326 IAC 2-1.1-5 (Air Quality Requirements), the formaldehyde emissions from each combustion turbine and duct burner shall not exceed 0.00036 pounds of formaldehyde per MMBtu, excluding startup and shutdown.

D.2.13 Ammonia Limitations

Pursuant to 326 IAC 2-1.1-5 (Air Quality Requirements), the ammonia emissions from each combustion turbine stack shall not exceed ten (10) ppmvd corrected to 15% O₂.

D.2.14 Preventive Maintenance Plan [326 IAC 1-6-3]

A Preventive Maintenance Plan, in accordance with Section C - Preventive Maintenance Plan, of this permit, is required for each combustion turbine and its control device.

Compliance Determination Requirements

D.2.15 Performance Testing

- (a) Pursuant to 326 IAC 3-5 the Permittee shall conduct a performance test, no later than one-hundred and eighty days (180) after the facility startup or monitor installation, on the combustion turbine exhaust stack (E11A, E12A, E21A, and E22A) in order to certify the continuous emission monitoring systems for NO_x and CO.
- (b) Within sixty (60) days after initial startup, but no later than one-hundred and eighty (180) days after initial startup, the Permittee shall perform formaldehyde stack test for each combustion turbine stack (E11A, E12A, E21A, and E22A) utilizing a method approved by the Commissioner when operating at 60%, 75%, and 100% load. These tests shall be performed in accordance with Section C – Performance Testing, in order to verify the formaldehyde emission factor specified in condition D.2.12.
- (c) Within sixty (60) days after initial startup, but no later than one-hundred and eighty (180) days after initial startup, the Permittee shall perform NO_x and CO stack tests for each combustion turbine stack (E11A, E12A, E21A, and E22A) during a startup/shutdown period, utilizing methods approved by the Commissioner. These tests shall be performed in accordance with Section C – Performance Testing, in order to document compliance with Conditions D.2.5.
- (d) Within sixty (60) days of achieving maximum production rate, but no later than one-hundred and eighty (180) days after initial startup, the Permittee shall conduct NO_x and SO₂ stack tests for each combustion turbine stack (E11A, E12A, E21A, and E22A) utilizing methods approved by the Commissioner. These tests shall be performed in accordance with 40 CFR 60.335 and Section C – Performance Testing, in order to document compliance with Condition D.2.10.
- (e) Within sixty (60) days after initial startup, but no later than one-hundred and eighty (180) days after initial startup, the Permittee shall perform PM, PM₁₀ (filterable and condensable), ammonia, and VOC stack tests for each combustion turbine stack (E11A, E12A, E21A, and E22A) utilizing methods approved by the Commissioner. These tests shall be performed in accordance with 40 CFR 60.335, 40 CFR 60.48(a), and Section C – Performance Testing, in order to document compliance with D.2.2(b), D.2.9, and D.2.13.
- (f) IDEM, OAQ and VCAPC retain the authority under 326 IAC 2-1-4(f) to require the Permittee to perform additional and future compliance testing as necessary.

D.2.16 40 CFR Part 60, Subpart GG Compliance Requirements (Stationary Gas Turbines)

Pursuant to 40 CFR Part 60, Subpart GG (Stationary Gas Turbines), the Permittee shall monitor the nitrogen and sulfur content of the natural gas on a monthly basis as follows:

- (a) Determine compliance with the nitrogen oxide and sulfur dioxide standards in 40 CFR 60.332 and 60.333(a), per requirements described in 40 CFR 60.335(c);
- (b) Determine the sulfur content of the natural gas being fired in the turbine by ASTM Methods D 1072-80, D 3030-81, D 4084-82, or D 3246-81. The applicable ranges of some ASTM methods mentioned are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Administrator; and
- (c) Determine the nitrogen content of the natural gas being fired in the turbine by using analytical methods and procedures that are accurate to within 5 percent and are approved by the Administrator.

The analyses required above may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor or any other qualified agency.

Owners, operators or fuel vendors may develop custom fuel schedules for determination of the nitrogen and sulfur content based on the design and operation of the affected facility and the characteristics of the fuel supply. These schedules shall be substantiated with data and must be approved by the Administrator before they can be used to comply with the above requirements.

D.2.17 Continuous Emission Monitoring (CEMs)

- (a) The owner or operator of a new source with an emission limitation or permit requirement established under 326 IAC 2-5.1-3 and 326 IAC 2-2, shall be required to install a continuous emissions monitoring system or alternative monitoring plan as allowed under the Clean Air Act and 326 IAC 3-5-1(d).
- (b) The Permittee shall install, calibrate, certify, operate and maintain a continuous emission monitoring system for NO_x and CO, for stacks designated as E11A, E12A, E21A and E22A in accordance with 326 IAC 3-5-2 and 3-5-3.
 - (1) The continuous emission monitoring system (CEMS) shall measure NO_x and CO emissions rates in pounds per hour and parts per million (ppmvd) corrected to 15% O₂. The use of CEMS to measure and record the NO_x and CO hourly limits, is sufficient to demonstrate compliance with the limitations established in the BACT analysis and set forth in the permit. To demonstrate compliance with the NO_x limit, the source shall take an average of the parts per million (ppmvd) corrected to 15% O₂ over a three (3) hour averaging period. To demonstrate compliance with the CO limit, the source shall take an average of the parts per million (ppmvd) corrected to 15% O₂ over a twenty four (24) hour averaging period. The source shall maintain records of the parts per million and the pounds per hour.
 - (2) The Permittee shall determine compliance with Condition D.2.5 utilizing data from the NO_x, CO, and O₂ CEMS, the fuel flow meter, and Method 19 calculations.

- (3) The Permittee shall submit to IDEM, OAQ, within ninety (90) days after monitor installation, a complete written continuous monitoring standard operating procedure (SOP), in accordance with the requirements of 326 IAC 3-5-4.
- (4) The Permittee shall record the output of the system and shall perform the required record keeping, pursuant to 326 IAC 3-5-6, and reporting, pursuant to 326 IAC 3-5-7.
- (c) Pursuant to 40 CFR 60.47(d), the Permittee shall install, calibrate, certify and operate continuous emissions monitors for carbon dioxide or oxygen at each location where nitrogen oxide emissions are monitored.

Record Keeping and Reporting Requirements [326 IAC 2-5.1-3(e)(2)] [326 IAC 2-6.1-5(a)(2)]

D.2.18 Record Keeping Requirements

- (a) To document compliance with Conditions D.2.2, D.2.5 through D.2.8, and D.2.11, the Permittee shall maintain records of the following:
 - (1) Amount of natural gas combusted (in MMCF) per turbine during each month.
 - (2) Percent sulfur of the natural gas.
 - (3) Heat input on a lower heating value basis of each turbine on a 30-day rolling average.
- (b) To document compliance with Condition D.2.5, the Permittee shall maintain records of the following:
 - (1) The type of operation (i.e. startup or shutdown) with supporting operational data
 - (2) The total number of minutes for startup or shutdown per 24-hour averaging period per turbine
 - (3) The CEMS data, fuel flow meter data, and Method 19 calculations corresponding to each startup and shutdown period.
- (c) To document compliance with Conditions D.2.6 and D.2.7, the Permittee shall maintain records of the emission rates of NO_x and CO in pounds per hour and parts per million (ppmvd) corrected to 15% oxygen.
- (d) To document compliance with Condition D.2.18, the Permittee shall maintain records, including raw data of all monitoring data and supporting information, for a minimum of five (5) years from the date described in 326 IAC 3-5-7(a). The records shall include the information described in 326 IAC 3-5-7(b).
- (e) To document compliance with D.2.10, the Permittee shall maintain records of the natural gas analyses, including the sulfur and nitrogen content of the gas, for a period of three (3) years.

- (f) All records shall be maintained in accordance with Section C – General Record Keeping Requirements, of this permit.

D.2.19 Reporting Requirements

The Permittee shall submit the following information on a quarterly basis:

- (a) Records of excess NO_x and CO emissions (defined in 326 IAC 3-5-7 and 40 CFR Part 60.7) from the continuous emissions monitoring system. These reports shall be submitted within thirty (30) calendar days following the end of each calendar quarter and in accordance with Section C – General Reporting Requirements of this permit.
- (b) The Permittee shall report periods of excess emissions, as required by 40 CFR 60.334(c)
- (c) A quarterly summary of the CEMs data to document compliance with D.2.6, and D.2.7 shall be submitted to the address listed in Section C – General Reporting Requirements, of this permit, within thirty (30) days after the end of the quarter being reported.
- (d) A quarterly summary of the total number of startup and shutdown hours of operation and corresponding startup and shutdown emissions to document compliance with Condition D.2.5, shall be submitted to the address listed in Section C – General Reporting Requirements, of this permit, within thirty (30) days after the end of the quarter being reported.

SECTION D.3 FACILITY CONDITIONS – Natural Gas Conditioning Heaters

Facility Description [326 IAC 2-5.1-3]

Five (5) natural gas conditioning heaters, designated NGCH1, NGCH2, NGCH3, NGCH4, NGCH5 with a maximum heat input capacity of 5 MMBtu/hr (per unit on a higher heating value basis), and exhausts to stacks E7, E8, E9, E10, E11 respectively.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards

D.3.1 Opacity Limitations

Pursuant to 326 IAC 5-1-2, the Permittee shall not cause the average opacity of the gas heater stacks to exceed twenty percent (20%) in any one (1) six (6) minute period. The opacity standards apply at all times, except during periods of startup, shutdown, or malfunction.

D.3.2 Best Available Control Technology for the Natural Gas Conditioning Heaters:

Pursuant to 326 IAC 2-2 (PSD Requirement), the source shall comply with the following:

- (a) Use natural gas as the only fuel for the gas heaters.
- (b) Perform good combustion practices.
- (c) The combined natural gas usage from the five (5) natural gas conditioning heaters shall not

exceed 144.8 MMSCF per year, based on a twelve (12) consecutive month period.

Record Keeping and Reporting Requirements [326 IAC 2-5.1-3(e)(2)] [326 IAC 2-6.1-5(a)(2)]

D.3.3 Record Keeping Requirements

- (a) To document compliance with Conditions D.3.2, the Permittee shall maintain records of the amount of natural gas combusted by the Natural Gas Conditioning Heaters during each month.
- (b) All records shall be maintained in accordance with Section C – General Record Keeping Requirements.

D.3.4 Reporting Requirements

The Permittee shall submit on a quarterly basis a summary of the information to document compliance with Condition D.3.2 to the addresses listed in Section C - General Reporting Requirements, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported.

SECTION D.4 FACILITY CONDITIONS – Backup Equipment

- (a) Two (2) diesel fire pumps, with a rating of 267 horsepower (hp).
- (b) Two (2) diesel emergency generators, with a rating of 1,475 horsepower (hp).

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards

D.4.1 BACT Limitation for Fire Pumps

Pursuant to 326 IAC 2-2 (PSD Requirements) the two (2) diesel fire pumps shall comply with the following:

- (a) The total input of the fire pumps shall be limited to 6,569 gallons per twelve (12) consecutive month period, rolled on a monthly basis.

- (b) The sulfur content of the diesel fuel used by the fire pump shall not exceed 0.05 percent by weight.
- (c) Perform good combustion practice.

D.4.2 BACT Limitation for Emergency Generators

Pursuant to 326 IAC 2-2 (PSD Requirements) the two (2) emergency generators shall comply with the following:

- (a) The total input of the fire pumps shall be limited to 37,847 gallons per twelve (12) consecutive month period, rolled on a monthly basis.
- (b) The sulfur content of the diesel fuel used by the fire pump shall not exceed 0.05 percent by weight.
- (c) Perform good combustion practice.

Compliance Determination Requirements

D.4.3 Performance Testing

The Permittee is not required to test these emissions units by this permit. However, IDEM may require compliance testing when necessary to determine if the emissions unit is in compliance. If testing is required by IDEM or VCAPC, compliance shall be determined by a performance test conducted in accordance with Section C - Performance Testing.

Record Keeping and Reporting Requirements [326 IAC 2-5.1-3(e)(2)] [326 IAC 2-6.1-5(a)(2)]

D.4.4 Record Keeping Requirements

To document compliance with Conditions D.4.1 and D.4.2, the Permittee shall maintain records of the following:

- (1) Amount of diesel fuel combusted each month in the two (2) fire pumps.
- (2) Amount of diesel fuel combusted each month in the two (2) emergency generators.
- (3) The percent sulfur content of the diesel fuel.

D.4.5 Reporting Requirements

A quarterly summary of the information to document compliance with D.4.1 and D.4.2 shall be submitted to the address listed in Section C – General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported.

MALFUNCTION REPORT

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY FAX NUMBER - 317 233-5967

**This form should only be used to report malfunctions applicable to Rule 326 IAC 1-6
and to qualify for the exemption under 326 IAC 1-6-4.**

THIS FACILITY MEETS THE APPLICABILITY REQUIREMENTS BECAUSE IT HAS POTENTIAL TO EMIT 25 LBS/HR PARTICULATE MATTER ?_____, 100 LBS/HR VOC ?_____, 100 LBS/HR SULFUR DIOXIDE ?_____, OR 2000 LBS/HR OF ANY OTHER POLLUTANT ?_____. EMISSIONS FROM MALFUNCTIONING CONTROL EQUIPMENT OR PROCESS EQUIPMENT CAUSED EMISSIONS IN EXCESS OF APPLICABLE LIMITATION _____.

THIS MALFUNCTION RESULTED IN A VIOLATION OF: 326 IAC _____ OR, PERMIT CONDITION # _____ AND/OR PERMIT LIMIT OF _____

THIS INCIDENT MEETS THE DEFINITION OF 'MALFUNCTION' AS LISTED ON REVERSE SIDE ? Y N

THIS MALFUNCTION IS OR WILL BE LONGER THAN THE ONE (1) HOUR REPORTING REQUIREMENT ? Y N

COMPANY : _____ PHONE NO. () _____
LOCATION: (CITY AND COUNTY) _____
PERMIT NO. _____ AFS PLANT ID: _____ AFS POINT ID: _____ INSP: _____
CONTROL/PROCESS DEVICE WHICH MALFUNCTIONED AND REASON: _____

DATE/TIME MALFUNCTION STARTED: ____/____/20____ AM / PM

ESTIMATED HOURS OF OPERATION WITH MALFUNCTION CONDITION: _____

DATE/TIME CONTROL EQUIPMENT BACK-IN SERVICE ____/____/20____ AM/PM

TYPE OF POLLUTANTS EMITTED: TSP, PM-10, SO₂, VOC, OTHER: _____

ESTIMATED AMOUNT OF POLLUTANT EMITTED DURING MALFUNCTION: _____

MEASURES TAKEN TO MINIMIZE EMISSIONS: _____

REASONS WHY FACILITY CANNOT BE SHUTDOWN DURING REPAIRS:

CONTINUED OPERATION REQUIRED TO PROVIDE ESSENTIAL* SERVICES: _____

CONTINUED OPERATION NECESSARY TO PREVENT INJURY TO PERSONS: _____

CONTINUED OPERATION NECESSARY TO PREVENT SEVERE DAMAGE TO EQUIPMENT: _____

INTERIM CONTROL MEASURES: (IF APPLICABLE) _____

MALFUNCTION REPORTED BY: _____ TITLE: _____
(SIGNATURE IF FAXED)

MALFUNCTION RECORDED BY: _____ DATE: _____ TIME: _____

**Please note - This form should only be used to report malfunctions
applicable to Rule 326 IAC 1-6 and to qualify for
the exemption under 326 IAC 1-6-4.**

PAGE 1 OF 2

326 IAC 1-6-1 Applicability of rule

Sec. 1. This rule applies to the owner or operator of any facility required to obtain a permit under 326 IAC 2-5.1 or 326 IAC 2-6.1.

326 IAC 1-2-39 "Malfunction" definition

Sec. 39. Any sudden, unavoidable failure of any air pollution control equipment, process, or combustion or process equipment to operate in a normal and usual manner.

***Essential services** are interpreted to mean those operations, such as, the providing of electricity by power plants. Continued operation solely for the economic benefit of the owner or operator shall not be sufficient reason why a facility cannot be shutdown during a control equipment shutdown.

If this item is checked on the front, please explain rationale:

**Indiana Department of Environmental Management
Office of Air Quality
Compliance Data Section and Vigo County Air Pollution Control
Quarterly Report**

Company Name: Mirant Sugar Creek LLC
Location: 5900 Darwin Road, West Terre Haute, IN 47885
Permit No.: CP-167-15295-00123
Source: Natural Gas Conditioning Heaters (five (5) units)
Limit: 144.8 MMCF per twelve (12) consecutive month period

Year: _____

Month	Column 1	Column 2	Column 1 + 2
	This Month	Previous 11 months	12 Month Total

9 No deviation occurred in this quarter.

9 Deviation/s occurred in this quarter.
 Deviation has been reported on:

Submitted by: _____
Title / Position: _____
Signature: _____
Date: _____
Phone: _____

**Indiana Department of Environmental Management
Office of Air Quality
Compliance Data Section and Vigo County Air Pollution Control
Quarterly Report**

Company Name: Mirant Sugar Creek LLC
Location: 5900 Darwin Road, West Terre Haute, IN 47885
Permit No.: CP-167-12208-00123
Source: Two (2) emergency diesel fire pump
Limit: 6,569 gallons per twelve (12) consecutive month period

Year: _____

Month	Diesel Fuel Oil Usage (gallons/month)	Diesel Fuel Oil Usage for previous month(s) (gallons)	Diesel Fuel Oil Usage for twelve month period (gallons)

9 No deviation occurred in this quarter.

9 Deviation/s occurred in this quarter.
Deviation has been reported on:

Submitted by: _____
Title / Position: _____
Signature: _____
Date: _____
Phone: _____

**Indiana Department of Environmental Management
Office of Air Quality
Compliance Data Section and Vigo County Air Pollution Control**

Quarterly Report

Company Name: Mirant Sugar Creek LLC
Location: 5900 Darwin Road, West Terre Haute, IN 47885
Permit No.: CP-167-12208-00123
Source: Two (2) emergency generators
Limit: 37,847 gallons per twelve (12) consecutive month period

Year: _____

Month	Diesel Fuel Oil Usage (gallons/month)	Diesel Fuel Oil Usage for previous month(s) (gallons)	Diesel Fuel Oil Usage for twelve month period (gallons)

9 No deviation occurred in this quarter.

9 Deviation/s occurred in this quarter.
Deviation has been reported on:

Submitted by: _____
Title / Position: _____
Signature: _____
Date: _____
Phone: _____

Mirant Sugar Creek LLC
West Terre Haute, Indiana
Permit Reviewer: David Howard

First Notice Only Change No: 167-15906
Change by: Janet Mobley

Page 44 of 47
CP-165-10476
ID-165-00022

**Indiana Department of Environmental Management
Office of Air Quality
Compliance Data Section and Vigo County Air Pollution Control
Quarterly Report**

Company Name: Mirant Sugar Creek LLC
Location: 5900 Darwin Road, West Terre Haute, IN 47885
Permit No.: CP-167-12208-00123
Source: Four (4) natural gas combustion turbines operating in simple cycle
Limit: Two (2) hours per startup, and 250 hours per year for startups. Two (2) hours per shutdown, and 42 hours per year for shutdowns.

Month: _____ Year _____
Total hours from previous month(s) startup _____ shutdown _____
Total hours per year for startup and shutdown for 12 month period _____

Day/ Turbine	Startup				Shutdown				Day/ Turbine	Startup				Shutdown			
	1	2	3	4	1	2	3	4		1	2	3	4	1	2	3	4
1									17								
2									18								
3									19								
4									20								
5									21								
6									22								
7									23								
8									24								
9									25								
10									26								
11									27								
12									28								
13									29								
14									30								
15									31								

Mirant Sugar Creek LLC
West Terre Haute, Indiana
Permit Reviewer: David Howard

First Notice Only Change No: 167-15906
Change by: Janet Mobley

Page 45 of 47
CP-165-10476
ID-165-00022

16									Total								
----	--	--	--	--	--	--	--	--	-------	--	--	--	--	--	--	--	--

? No deviation occurred in this month ? Deviation/s occurred in this month.
Deviation has been reported on:

Submitted by: _____
Title/Position: _____
Signature: _____
Date: _____
Phone: _____

Mirant Sugar Creek LLC
West Terre Haute, Indiana
Permit Reviewer: David Howard

First Notice Only Change No: 167-15906
Change by: Janet Mobley

Page 46 of 47
CP-165-10476
ID-165-00022

**Indiana Department of Environmental Management
Office of Air Quality
Compliance Data Section and Vigo County Air Pollution Control**

Quarterly Report

Company Name: Mirant Sugar Creek LLC
Location: 5900 Darwin Road, West Terre Haute, IN 47885
Permit No.: CP-167-12208-00123
Source: Four (4) natural gas combustion turbines operating in combined cycle
Limit: Four (4) hours per startup, and 500 hours per year for startups. Four (4) hours per shutdown, and 83 hours per year for shutdowns.

Month: _____ Year: _____
Total hours from previous month(s) startup _____ shutdown _____
Total hours per year for startup and shutdown for 12 month period _____

Day/ Turbine	Startup				Shutdown				Day/ Turbine	Startup				Shutdown			
	1	2	3	4	1	2	3	4		1	2	3	4	1	2	3	4
1									17								
2									18								
3									19								
4									20								
5									21								
6									22								
7									23								
8									24								
9									25								
10									26								
11									27								
12									28								
13									29								
14									30								
15									31								
16									Total								

? No deviation occurred in this month ? Deviation/s occurred in this month.
Deviation has been reported on:

Submitted by: _____
Title/Position: _____
Signature: _____
Date: _____

Mirant Sugar Creek LLC
West Terre Haute, Indiana
Permit Reviewer: David Howard

First Notice Only Change No: 167-15906
Change by: Janet Mobley

Page 47 of 47
CP-165-10476
ID-165-00022

Phone:
